



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2023/NDZ/ 411

Dated: 09/06/2023

FIRE SAFETY CERTIFICATE

Certified that the Vivekanand Public School located at B- Block, Anand Vihar, Delhi-110092, comprised of basement, ground plus three upper floors, owned/occupied by New Vivek Education Society has already been issued FSC vide letter no. F.6/DFS/MS/2019/School/NDZ/993 dated 10/05/2019. The premises was re-inspected by the officer concerned of fire service on 25/05/2023 in the presence of Ms. Ashima Jhamb, Principal of the school and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 09/06/23.. for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....09/06/2023.....at New Delhi by.

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

To,

The Principal
Vivekanand Public School located at B- Block, Anand Vihar, Delhi-110092

Copy:-

The Dy. Director of Education,
D- Block, Anand Vihar, Delhi-110092

Conditions for the validity of Fire Safety Certificate:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry