

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"




DELHI JAL BOARD, GOVT. OF N.C.T. DELHI
 QUALITY CONTROL LABORATORY,
 TRANS YAMUNA REGION TAHIRPUR DELHI-110093

ACWA-TYR
 Diary No. 387

10/5/2022

 जल एवं स्वच्छता से जी



Licence No- CRO/QM/L-8004274 as per IS/ISO 9001:2015

DATE: 07-05-2022

NO: DJB/ACWA(TYR)/2022.....

Analysis report of DJB Supply water samples collected from (1) Inlet and (2) Outlet M/S Vivekanand Public School, B Block, Anand Vihar, Delhi- 110092 for drinking purpose.

Ref. No:-VPS/2022/1399 on dated 21.04.2022 via Challan No:1 -34, dated:- 27/04/2022,
 Challan No:2 -39, dated:- 29/04/2022

Date of collection:-04/05/2022

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1) INLET	(2) OUTLET
A. Physical Examination						
1.	Colour	-	Clear	Clear
2.	Odour	-	Chlor.	Chlor.
3.	Turbidity	1.0	5.0	NTU	0.86	1.25
4.	pH Value	6.5-8.5	--	-	7.5	7.6
5.	Electrical Conductivity	--	--	µs/cm	180	186
6.	Total Dissolved Solids	500	2000	mg/l	117	120
B. Chemical Examination						
7.	P th Alkalinity	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	52	56
9.	Total Hardness	200	600	mg/l	80	76
10.	Calcium Hardness	mg/l	52	50
11.	Magnesium Hardness	mg/l	28	26
12.	Calcium as (Ca)	75	200	mg/l	20.8	20
13.	Magnesium as (Mg)	30	100	mg/l	6.72	6.24
14.	Ammonical Nitrogen	0.5	NO RELAXATION	mg/l	N.D	N.D
15.	Nitrite	mg/l	N.D	N.D
16.	Nitrate	45	NO RELAXATION	mg/l	1.9	1.3
17.	Sulphate	200	400	mg/l	9.2	9.6
18.	Chloride	250	1000	mg/l	10	8
19.	Fluoride	1.0	1.5	mg/l	0.28	0.37
20.	Total Iron	1.0	NO RELAXATION	mg/l	0.10	0.12
21.	Residual Chlorine	0.2	1.0	mg/l	0.52	0.37
C. Bacteriological Examination						
22.	Coliform count	Absent	NO RELAXATION	MPN/100ml	0	0

This Report Pertains To The Particular Sample Only

REMARKS:- On the basis of above tested parameters, both water samples conforms BIS: 10500-2012 and can be considered fit for drinking purpose .

A/CHEMIST

CHEMIST

K. Singh
 7/5/2022
 ACWA (TYR)
 Asstt. Chief Water Analyst
 D.J.B. Govt. of N.C.T. of Delhi
 Quality Control Zonal Laboratory (Tyr)
 Tahir Pur Dilshad Garden, Delhi-93

MUNICIPAL CORPORATION OF DELHI
Public Health Department
Shahdara (South) Zone
419, Udyog Sadan, Patparganj Industrial Area Delhi-110092

No. DHO/Shah.(S)/2023/D-473

Dated: 26/7/23


School Health Certificate

1. Name of School	: Vivekanand Public School Sr.Sec School
2. Location of the School	: B-Block Anand Vihar Delhi-110092
3. No. of Students	: 1472
4. No. of Doors in each room	: Provided
5. No. of Fans in each room	: Provided
6. Building Structure	: Pucca
7. Electricity	: BSES
8. Water Supply	: DJB Bill
9. No. of Urinals and WCS	: Provided
10. No. of Teaching Staff	: 69
11. No. of Tab	: Provided
12. No. of Rooms	: 65

At the time of inspection, school is found running under sanitary and hygiene conditions. This certificate has no bearing on unauthorized construction of the premises if any and on any dispute regarding title of land.

This certificate/NOC is valid for (01) one year only.

The Principal
Vivekanand Public School Sr.Sec School
B -Block Anand Vihar Delhi-110092


Deputy Health Officer
Shahdara (South) Zone
DEPUTY HEALTH OFFICER
MUNICIPAL CORPORATION OF DELHI
SHAHDARA (SOUTH) ZONE